

COMPANY NAME	List Type	RULE 1146.2 CERTIFIED MODELS	CONTACT Phone/E-mail/Web
Parker Boiler Company	Current Web List (July 29, 2009)	103-9.5L, 103-15L, 103-20L, 103-25L, 30LA, 40LA, 50LA, 60LA, HT180L, HT247L, T300LR, T395L, T395LR, WH395LR, HT395L, HT432L, WH490L, T490L, T490LR, HT528L, T600L, T600LR, WH600L, HT672L, WH730L, T760L, T760LR, HT864L, T970L, T970LR, WH970L, HT1008L, WH1210L, HT1296L, WH1410L, T1460L, T1460LR, HT1536L, T1730L, T1730LR, WH1900L, HT1920L, T2160L(1990), WH2270L(1990), HT2304L(1990), T2600L(1990), T2600LR(1990), HT2640L(1990), WH2650L(1990), T2970L(1990), WH3000L(1990), HT3120L(1990), HT3456L(1990), T3600L(1990), T3900L(1990), HT4032L(1990), T4600L(1990), T1995LR, T300L, WH300L, T1140LR, HT126L, T1995L, 30L, 40L, 70L, 48L, 3LA, 7LA, 9.5LA, 20LA, WH300L, WH395L, WH490L, WH600L, WH730L, WH970L, WH1210L, WH1410L, WH1900L, HT126L, HT180L, HT247L, HT395L, HT432L, HT528L, HT672L, HT864L, HT1008L, HT1296L, HT1536L, HT1920L, G672R, G1008R, G1536R, G2304R	Greg Danenhauer (323) 727-9800 www.parkerboiler.com
	Type 2 (> 400,000--2,000,000 BTU/HR) (Complies with 14 ng/J or 20 ppm NOx @ 3% O2) (Effective 1/1/2010)	103-15L, 103-20L, 103-25L, HT432L, WH490L, T490L, T490LR, HT528L, T600L, T600LR, WH600L, HT672L, WH730L, T760L, T760LR, HT864L, T970L, T970LR, WH970L, HT1008L, WH1210L, HT1296L, WH1410L, T1460L, T1460LR, HT1536L, T1730L, T1730LR, WH1900L, HT1920L, T2160L (1990), WH2270L (1990), HT2304L(1990), T2600L (1990), T2600LR (1990), HT2640L (1990), WH2650 (1990), T2970L (1990), WH3000L (1990), HT3120L (1990), HT3456L (1990), T3600L (1990), T3900 (1990), HT4032L (1990), T4600L (1990), T1995LR, T1140LR, T1995L, 30L, 40L, 70L, 48L, G672, G1008R, G1536R, G2304R, T1140L **	
	Type 1 (<= 400,000 BTU/HR) (Complies with 14 ng/J or 20 ppm NOx @ 3% O2) (Effective 1/1/2012)	103-9.5L, HT180L, HT247L, T300LR, T395L, T395LR, WH395LR, HT395L, HT126L, WH395L, T300L, WH300L	
	Type 1 (Complies with 40 ng/J or 55 ppm NOx @ 3% O2) (Expires 12/31/2011)	3LA, 7LA, 9.5LA,	
	Type 2 (> 400,000--2,000,000 BTU/HR) (Complies with 30 ppm NOx @ 3% O2, or 0.037 lbs NOx/million BTU/Hr) (Sell-through until 12/31/2010)	20LA,30LA, 40LA, 50LA, 60LA	
		** INCLUDED ON SCAQMD CERT LETTER, EXCLUDED FROM WEB SITE	