



NOTE: VENT OUTLET NOT SHOWN FOR CLARITY

NOTE: ON WATER LINES, MATERIAL TO FIRST SHUTOFF VALVE SHOULD BE TYPE "L" COPPER.

USED ON <i>LOW TEMPERATURE SYSTEMS</i>		PART NAME <i>BOILER PIPING DIAGRAM</i>	
FOR HEAT PUMP SYSTEMS OR SWIM POOL WITH HEATING HOT WATER IN 60F - 100F TEMPERATURE RANGE			
DR. <i>EK</i>	DATE <i>5D</i>	PARKER BOILER CO. 5930 BANDINI BOULEVARD LOS ANGELES, CALIFORNIA 90040	SCALE <i>NONE</i>
CH. <i>MJL</i>			SUPERCEDES NO. <i>4/88</i>
APPROVED			FILE DESIGNATION <i>210inst-HP.dwg</i>
			DRWG. NO. <i>A-210-INST-HP</i>