

NOTICE FOR BOILER PERMIT REQUIREMENTS
PARKER STEAM BOILERS: 10 HP & LARGER EXCEEDING 15 PSI & 9.5 HP AND SMALLER EXCEEDING 100 PSI
FOR INSTALLATIONS IN CALIFORNIA (DOES NOT APPLY IN CITY OF LOS ANGELES)

STATE OF CALIFORNIA REQUIREMENTS:

(Calif. Code of Regulations Title 8 Subchapter 2. Boiler and Fired Pressure Vessel Safety Orders.)

The following sizes of Parker Steam Boilers REQUIRE STATE Field INSPECTION and a "PERMIT TO OPERATE" issued by an Authorized State Commissioned Boiler Inspector employed by the State or an Authorized Boiler Insurance Company per State Safety Orders §770 and §780.

1. 10 HP and Larger High Pressure Steam Boilers exceeding 15 PSI Pressure.
2. 9.5 HP and Smaller High Pressure Steam Boilers exceeding 100 PSI Pressure.

WARNING: It is a **MISDEMEANOR OFFENSE IN THE STATE OF CALIFORNIA** (Labor Code 7750) to Operate a Boiler without the initial Inspection and a "Permit to Operate" unless Exempt. Before installing the Boiler, be certain all required Permits are obtained. Before placing the Boiler in service, be sure that all approvals are obtained and a "**PERMIT TO OPERATE**" is obtained from the Boiler Installation Jurisdiction. **OPERATING PERMITS MUST BE POSTED AT OR NEAR THE BOILER.**

The California State Boiler Safety Orders established the minimum Standards on Boilers installed in the State of California. State Safety Order §780 specifies that a Boiler may not be placed in service without a "PERMIT TO OPERATE"; unless, (1) The Boiler is specifically exempt from Annual Inspection and the "Permit to Operate" (State Safety Order §771); or (2) A Request for a "Permit to Operate" has been made and it has not yet been acted upon. The Permit must be issued by an Authorized State Commissioned Boiler Inspector employed by the State of California, Division of Industrial Relations, DOSH, or by an Authorized Boiler Insurance Company or a City having a Boiler Inspection Department.

NOTE: The owner is responsible that all boilers, whether exempt or not, must comply with all other provisions of the State Safety Orders per §781. These include proper construction, installation and direct supervision by a person responsible for (1) Safe operation by a competent attendant, and (2) Proper maintenance of the boiler and its appurtenances. Boilers requiring a State Permit to Operate while in operation shall not be left unattended nor operated by a timeclock per §781.

OTHER REQUIREMENTS

Before installing the Boiler, check with the Local Building Jurisdiction to be certain that all Installation Permits are obtained and that the planned installation conditions conform to the required Codes. Most cities and Areas require that the installer hold a valid Contractor's License.

It is very important that all Boilers and Pressure Vessels be installed in full compliance with the applicable Local, City or County Codes that come under the Jurisdiction of the Local Building or Plumbing Inspection Departments including:

1. Installation Permits and Inspection Approval.
2. Boiler Room Requirements.
3. Permits and Requirements on utilities including gas, electrical and Water Connections.
4. Boiler Venting, Air Quality, Drains and Plumbing Connections.

All Parker Boilers are manufactured in accordance with the A.S.M.E. Boiler Code and registered with the National Board. The Boiler and Controls standardly comply with the California State Boiler Safety Orders and recognized Standards. If there are any questions as to the acceptability of the Product as furnished, immediately contact the Manufacturer or Representative for clarification.

Before Installing the Boiler carefully read the Manufacturer's Installation Instructions furnished with the Boiler which cover the minimum standards for proper installation. Before placing the boiler in service all required Permits and Inspection Approvals must be obtained. The final check out and startup of the Boiler should be by competent knowledgeable personnel. The Boiler Operation and Maintenance Manual as furnished with the Boiler should be turned over to the Owner or person responsible for the Operation and Maintenance.

IT IS IMPORTANT THAT THIS NOTICE BE FORWARDED TO THE INSTALLER AND OWNER SO THAT ALL CODE REQUIREMENTS CAN BE FULLY INVESTIGATED AND COMPLIED WITH TO ELIMINATE EXPENSIVE CHANGES AND CODE VIOLATIONS. PLEASE CONTACT THE MANUFACTURER OR PARKER REPRESENTATIVE IF YOU HAVE ANY QUESTIONS.

PARKER BOILER CO.
5930 Bandini Blvd.
Los Angeles, CA 90040
(323) 727-9800

Calif. Permits Required (Not LA)
CA-1 (High Pressure Steam Boilers)
OK6

LIST OF OFFICES TO CONTACT FOR BOILER PERMIT AND INSPECTION
(IF YOUR INSPECTION IS NOT HANDLED BY AN AUTHORIZED BOILER INSURANCE CO.)

Southern California State Offices
California State Boiler and Pressure Vessel Inspection Department

District Office

Santa Ana

(For Southern California Inspections)
Department of Industrial Relations
Division of Occupational Safety and Health
Pressure Vessel Unit South
2000 E. McFadden Ave., Suite 215
Santa Ana, CA 92705
Ph: (714) 567-7208
Fax: (714) 567-7297

NOTE: For installations in the City of Los Angeles only contact:

City of Los Angeles

Department of Building & Safety
Boiler & Pressure Vessel Inspection
Room 2010, 3550 Wilshire Blvd
Los Angeles, CA 90010
Ph: (213) 252-3021

Northern California State Offices
California State Boiler and Pressure Vessel Inspection Department

District Office & Headquarters

Oakland

(For Northern California Inspections)
Boiler & Pressure Vessel Unit (DIR/DOSH)
State of California
Elihu Harris State Building
1515 Clay St, Suite 1302
Oakland, CA 94612
Ph: (510) 622-3052
Fax: (510) 622-3063