

**NOTICE FOR BOILER PERMIT REQUIREMENTS**  
**PARKER STEAM BOILERS: 9.5 HP & SMALLER NOT EXCEEDING 100 PSI & ALL SIZES NOT EXCEEDING 15 PSI**  
**PARKER HOT WATER BOILERS, THERMAL LIQUID HEATERS AND INDIRECT HEATERS**  
**FOR INSTALLATIONS IN CALIFORNIA (DOES NOT APPLY IN CITY OF LOS ANGELES)**

**STATE OF CALIFORNIA REQUIREMENTS**

(Calif. Code of Regulations Title 8 Subchapter 2. Boiler and Fired Pressure Vessel Safety Orders.)

The following sizes of Parker Steam Boilers, Hot Water Boilers and Heaters are EXEMPT from an initial and annual State Field INSPECTION and a "PERMIT TO OPERATE" per State Safety Order §771 when properly maintained and standardly fitted with all controls required in §763(d).

1. 9.5 and Smaller High Pressure Steam Boilers not exceeding 100 PSI pressure.
2. All sizes Low pressure Steam Boilers not exceeding 15 PSI pressure.
3. All sizes Hot Water Boilers regardless of pressure or temperature.
4. All sizes High Temperature Thermal Liquid Heaters.
5. All sizes Indirect Fired Water Heaters.

Even though these Boilers and Heaters are exempt from a State Field Inspection and a Permit to Operate, the owner is responsible that they comply with all other provisions of the State Safety Orders per §781. These include proper construction, installation, and direct supervision by a person responsible for: (1) Safe operation by a competent attendant, and (2) Proper maintenance of the boiler and its appurtenances.

**OTHER REQUIREMENTS**

Before installing the Boiler or Heater, check with the Local Building Jurisdiction to be certain that all Installation Permits are obtained and that the planned installation conditions conform to the required Codes. Most cities and Areas require that the installer hold a valid Contractor's License.

It is very important that all Boilers, Heaters and Pressure Vessels be installed in full compliance with the applicable Local, City or County Codes that come under the Jurisdiction of the Local Building or Plumbing Inspection Departments including:

1. Installation Permits and Inspection Approval.
2. Boiler Room Requirements.
3. Permits and Requirements on utilities including gas, electrical and Water Connections.
4. Boiler Venting, Air Quality, Drains and Plumbing Connections.

All Parker Boilers and Heaters are manufactured in accordance with the A.S.M.E. Boiler Code and registered with the National Board. The Boiler and Controls standardly comply with the California State Boiler Safety Orders and recognized Standards. If there are any questions as to the acceptability of the Product as furnished, immediately contact the Manufacturer or Representative for clarification.

Before Installing the Boiler or Heater carefully read the Manufacturer's Installation Instructions furnished with the Product which cover the minimum standards for proper installation. Before placing the Boiler or Heater in service, all required Permits and Inspection Approvals must be obtained. The final check out and startup of the Product should be by competent knowledgeable personnel. The Operation and Maintenance Manual as furnished with the Boiler or Heater should be turned over to the Owner or person responsible for Operation and Maintenance

**IT IS IMPORTANT THAT THIS NOTICE BE FORWARDED TO THE INSTALLER AND OWNER SO THAT ALL CODE REQUIREMENTS CAN BE FULLY INVESTIGATED AND COMPLIED WITH TO ELIMINATE EXPENSIVE CHANGES AND CODE VIOLATIONS. PLEASE CONTACT THE MANUFACTURER OR PARKER REPRESENTATIVE IF YOU HAVE ANY QUESTIONS.**

**PARKER BOILER CO.**  
**5930 Bandini Blvd.**  
**Los Angeles, CA 90040**  
**(323) 727-9800**

Calif. Exempt (Not LA)  
CA-2 (Steam and Hot Water Boilers and Heaters)