

**PARKER BOILER CO.**  
**IMPORTANT NOTICE ON BOILERS INSTALLED IN STATE OF NEVADA**  
**REQUIREMENTS FOR INSTALLATIONS APPLICATIONS AND BOILER OPERATING PERMIT**

The Nevada Regulations are mandatory and applicable on the following Boilers and Pressure Vessels:

1. All Steam Boilers and Hot Water Boilers in excess of 200,000 BTU heating capacity.
2. All Unfired Pressure Vessels exceeding 15 psig, 120 gallon capacity of 5 cubic feet in size.

**BEFORE INSTALLING A BOILER OR PRESSURE VESSEL:**

1. An Application for Installation must be filed with with the Mechanical Section of the Nevada Division of Occupational Safety and Health.
2. A copy of the Manufacturer's Data Report must accompany the application.

**BEFORE PLACING A BOILER OR PRESSURE VESSEL IN SERVICE:**

1. An "Operating Permit" must be obtained or temporary approval received from the Inspection Jurisdiction until the permit is acted upon.
2. The Inspection and Permit to Operate must be handled by a Nevada State Inspector or a Nevada Commissioned Inspector employed by an Insurance Company and Authorized by Mechanical Section.

**LOCAL CODES:**

It is also very important that the additional standards established by Local City or County Codes be fully complied with, including:

1. Boiler Installation Permits.
2. Boiler Room Requirements.
3. Permits and Requirements on Utilities, including Gas, Electrical, Water Vent and Plumbing.
4. All conditions to the particular installation must meet with the approval of the concerned Inspection Jurisdiction.

**BOILER OPERATIONS CERTIFICATE:**

A Boiler Operator's Certificate is not mandatory in the State of Nevada. However, Boiler Operator Certificates are given after successfully completing an examination. Examinations are given for the different classes of Boilers requiring attendance.

**NEVADA REGULATION NO. 618.298 - SUPERVISION OF BOILERS:**

1. Steam Boiler under the jurisdiction of the section which has safety valves set at pressures in excess of 5pounds per square inch must not be Operated unattended for periods in excess of the time required to evaporate the water at normal operating level to the lowest permissible water level.
2. When attendance of the boiler is required, the Boiler must be in the charge of a person qualified by technical training, experience and knowledge to start, operate and shut down the Boiler.
3. The Attendant shall personally check the operation of the Boiler, the necessary auxiliaries and the Water Level in the Boiler at intervals necessary to ensure the Safe Operation of the Boiler. The Boiler and its auxiliaries may not be left without checking for more than 60 minutes.
4. Steam Boilers exceeding 15 pounds per square inch must not be left unattended unless the Boiler is equipped with the following protective devices:
  - (a) A Low Water or Fuel Cutoff;
  - (b) An Automatic Feed Regulator;
  - (c) Fuel and damper regulators, including Safety Pilots for gas fuels and safe Combustion Controls for liquid fuels;
  - (d) An Audible Alarm to indicate Low Water; and
  - (e) A Pressure Control.

See below for the District Office to Contact for further information or if the Inspection and Permit is handled by a Boiler Inspector from the Nevada State Mechanical Section:

**STATE OF NEVADA**  
**DIVISION OF OCCUPATIONAL SAFETY AND HEALTH - MECHANICAL SECTION**

Administrative Office - Mechanical Section-DOSH  
1370 South Curry  
Carson City, Nevada 89710  
(702) 885-5249

**DISTRICT NO. II**  
4600 Kietzke Lane, Bldg. D, Suite 139  
Reno, Nevada 89502  
(702) 789-0471

**DISTRICT NO. III**  
4055 S. Spencer, Suite 128  
Las Vegas, Nevada 89158  
(702) 386-5230

**WARNING:** FAILURE TO OBTAIN AN "OPERATING PERMIT" OR COMPLY WITH THE NEVADA RULES AND REGULATIONS MAY RESULT IN SERIOUS PENALTIES TO THE OWNER OR USER.